

Noise Monitoring Data-Monthly Summary						
<b>Month and Year:</b>	Feb-20					
<b>Project:</b>	Central Station Main Works					
<b>EPL Licence Number:</b>	21148					
<b>EPL Weblink:</b>	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>					
<b>Specific EPL Monitoring Condition:</b>	M7.1- Noise Monitoring					
<b>Monitoring Location:</b>	<b>Number of Monitoring Events during the Month</b>	<b>Attended/Continuous Monitoring</b>	<b>Event Based Monitoring? (Y/N)</b>	<b>Measured Parameter: LAeq15mins (dB)</b>	<b>Predicted Parameter: LAeq15mins (dB)</b>	<b>Comment</b>
Chalmers St	16	Continuous	Yes	Max 77	73	Platform 23 edge beam works captured. Best achievable noise performance objectives met as identified in the CNVIS.
Chalmers St	10	Attended	Yes	Max 75	75	Day works at Eastern Entrance. Check for internal noise limits. Respite periods observed. Best achievable noise performance objectives met as identified in the CNVIS.
YHA	9	Continuous	Yes	Max 80	66	CSM works occurring, however only Train idling audible.