

Noise Monitoring Data-Monthly Summary						
Month and Year:	Feb-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	4	Attended	Yes	Max 72	71	Ambient noise from road and rail traffic.
30-38 Chalmers St (Internal)	2	Attended	Yes	55	60 (Internal)	Inside apartment. Works audible. Furniture moved during recording, typing on computer, fridge and a/c also audible.