

### Water Treatment Plant - Water Discharge Monitoring Data Summary

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	May 2020						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Web link	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH Averaged across all discharge events 6.5 - 8.5	TSS ≤ 50 mg/L	Oil and grease present (Y/N)	Comments
1/05/2020	59.54	1	Y	6.8	1.9	N	
2/05/2020	12.12	1	Y	6.7	2	N	
4/05/2020	30.23	1	Y	6.8	2.2	N	
5/05/2020	90.71	1	Y	6.9	1.8	N	
6/05/2020	79.56	1	Y	6.9	1.5	N	
7/05/2020	9.07	1	Y	6.8	3	N	
8/05/2020	23.2	1	Y	6.9	1.3	N	
9/05/2020	54.47	1	Y	6.9	1.2	N	
10/05/2020	1	1	Y	7.12	2	N	
11/05/2020	58.49	1	Y	6.9	1.08	N	
12/05/2020	25.17	1	Y	6.9	1.2	N	
13/05/2020	35.25	1	Y	6.8	1.5	N	
14/05/2020	45.34	1	Y	6.85	1.5	N	
15/05/2020	45.39	1	Y	7	1.3	N	
16/05/2020	30.25	1	Y	7.1	0.9	N	
17/05/2020	23.2	1	Y	6.9	1.1	N	
18/05/2020	40.31	1	Y	7.1	1.8	N	
19/05/2020	49.5	1	Y	7.4	1.5	N	

20/05/2020	47.44	1	Y	7.1	1.1	N
21/05/2020	98.86	1	Y	7	1.6	N
22/05/2020	261.2	1	Y	7.6	2.3	N
23/05/2020	49.41	1	Y	7.3	2.5	N
24/05/2020	43.32	1	Y	7.3	2.1	N
25/05/2020	195.31	1	Y	7.6	1.8	N
26/05/2020	321.72	1	Y	7.5	1.8	N
27/05/2020	100.83	1	Y	7.1	1.7	N
28/05/2020	47.39	1	Y	7.1	2	N
29/05/2020	95.89	1	Y	7.2	2.1	N
30/05/2020	67.58	1	Y	7	2	N
31/05/2020	26.27	1	Y	7.2	1.2	N