



Water Treatment Plant - Water Discharge Monitoring Data Summary

Month and Year	January 2020					
Project	Central Station Main Works					
EPL Licence Number	21148					
EPL Web link	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge					
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH <small>Averaged for all discharge event</small> 6.5 - 8.5 (Y/N)	TSS < 50 mg/L (Y/N)	Oil and grease present (Y/N)
17/01/2020	46	2	Y	Y	<10	N
18/01/2020	46	1	Y	Y	<10	N
20/01/2020	334	1	Y	Y	<10	N
22/01/2020	63	1	Y	Y	<10	N
28/01/2020	7	1	Y	Y	<10	N
31/01/2020	17	1	Y	Y	<10	N