

Noise Monitoring Data-Monthly Summary						
Month and Year:	Nov-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	42	Continuous	Yes	Max 75	72	Sawcutting of Platform 22
Chalmers St	3	Attended		Max 74	72	Sawcutting of Platform 22
YHA	25	Continuous	Yes	Max 79	60	CSM works occurring, however only Train idling audible.