

**Water Treatment Plant - Water Discharge Monitoring Data Summary**

<b>Month and Year</b>	December 2018 to December 2019					
<b>Project</b>	Central Station Main Works					
<b>EPL Licence Number</b>	21148					
<b>EPL Web link</b>	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>					
<b>Specific EPL Monitoring Condition:</b>	M2.1- Pollutant Discharge					
<b>Date</b>	<b>Discharge Point 1 = Stormwater 2 = Land</b>	<b>M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)</b>	<b>pH 6.5 - 8.5</b>		<b>Oil and grease present (Y/N)</b>	<b>Comments</b>
2/09/2019	2	Y	8.0	12	N	
10/09/2019	2	Y	8.5	7	N	
14/09/2019	2	Y	8.1	29	N	
17/09/2019	2	Y	7.6	46	N	
18/09/2019	2	Y	7.9	43	N	
18/09/2019	2	Y	8.1	47	N	
18/09/2019	2	Y	8.3	46	N	
19/09/2019	2	Y	7.2	42	N	
19/09/2019	2	Y	8.1	39	N	
19/09/2019	2	Y	7.9	36	N	
20/09/2019	2	Y	7.8	42	N	
20/09/2019	2	Y	7.6	44	N	
21/09/2019	2	Y	7.2	46	N	

No discharges from the Water Treatment Plant via discharge point 1 to the stormwater system during the reporting period. All stormwater was managed within the project EPL boundary.