

Noise Monitoring Data-Monthly Summary						
Month and Year:	Mar-20					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Web link:	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	18	Continuous	Yes	Max 73 (67 highest associated with CSM Works)	73	LAeq15min typically below 60dB throughout the month. Best achievable noise performance objectives met as identified in the CNVIS. Max LAeq15min not associated with CSM Works.