

Vibration Monitoring Data-Monthly Summary						
Month and Year:	Apr-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M7.2- Vibration Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: Peak particle Velocity (PPV) (mm/s)	Predicted Parameter: Peak particle Velocity (PPV) (mm/s)	Comment
TCAC	1	Continuous	No-limited site work consisting of hoarding installation.	<25mm/s	<7.5mm/s	The screening criteria of 7.5mm/s was exceeded on multiple occasions, however well below the conservative project vibration damage screening level for reinforced or framed structures of 25.0 mm/s. Typical works in the area consisted of hoarding installation. Compliant.