

Water Treatment Plant - Water Discharge Monitoring Data Summary

Month and Year	February 2020						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Weblink	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH <small>Averaged for all discharge event</small> 6.5 - 8.5 (Y/N)		Oil and grease present (Y/N)	Comments
3/02/2020	48	1	Y	Y	<10	N	
4/02/2020	54	1	Y	Y	<10	N	
5/02/2020	218	1	Y	Y	<10	N	
6/02/2020	250	1	Y	Y	<10	N	
7/02/2020	150	1	Y	Y	<10	N	
10/02/2020	778	1	Y	7.79	2.05	N	
11/02/2020	352	1	Y	7.68	2.38	N	
12/02/2020	81	1	Y	7.36	1.28	N	
13/02/2020	19	1	Y	7.19	1.3	N	
14/02/2020	60	1	Y	7.2	1.07	N	
17/02/2020	120	1	Y	7.26	1.69	N	
18/02/2020	114	1	Y	7.24	1.29	N	
19/02/2020	81	1	Y	7.19	1.39	N	
20/02/2020	51	1	Y	7.26	1.52	N	
21/02/2020	42	1	Y	7.21	2.06	N	
22/02/2020	4	1	Y	7.22	2.11	N	
24/02/2020	38	1	Y	7.29	1.74	N	
25/02/2020	41	1	Y	7.27	1.25	N	
27/02/2020	36	1	Y	7.09	2.55	N	
28/02/2020	9	1	Y	7.6	1.23	N	