

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	June 2020						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Web link	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH Averaged across all discharged events 6.5 - 8.5	TSS ≤ 50 mg/L	Oil and grease present (Y/N)	Comments
1/06/2020	56.5	1	Y	7.2	2.1	N	
2/06/2020	53.51	1	Y	7.3	1.7	N	
3/06/2020	24.25	1	Y	7.5	1.4	N	
4/06/2020	44.26	1	Y	7.9	1.2	N	
5/06/2020	20.1	2	Y	7.55	1.5	N	
6/06/2020	16.07	2	Y	7.95	2	N	
7/06/2020	88.38	2	Y	7.76	5	N	
8/06/2020	223.19	2	Y	6.9	5	N	Reported to EPA
9/06/2020	82.45	2	Y	7.5	5	N	
10/06/2020	184.71	2	Y	7.6	5	N	
11/06/2020	67.31	2	Y	8	2	N	
12/06/2020	60.58	1	Y	7.9	2.3	N	
13/06/2020	45.42	1	Y	8	2.5	N	
14/06/2020	123.17	1	Y	7.8	3	N	
15/06/2020	102.93	1	Y	7.28	2.3	N	
16/06/2020	23.2	1	Y	6.9	2.5	N	
17/06/2020	81.77	1	Y	7.35	2.7	N	

18/06/2020	57.54	1	Y	7.4	2.5	N
19/06/2020	28.26	1	Y	7.3	1.8	N
20/06/2020	29.26	1	Y	7.34	1.3	N
21/06/2020	53.51	1	Y	7.23	1.1	N
22/06/2020	33.36	1	Y	7.5	1.2	N
23/06/2020	36.3	1	Y	7.6	1.5	N
24/06/2020	40.17	1	Y	7.1	2.2	N
25/06/2020	22.12	1	Y	7.11	1.8	N
26/06/2020	52.3	1	Y	7.1	2	N
27/06/2020	18.13	1	Y	6.9	1	N
28/06/2020	25.17	1	Y	7.2	1	N
29/06/2020	86.47	1	Y	7.6	1.1	N
30/06/2020	38.18	1	Y	7.2	1.1	N