

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	July 2020						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Web link	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH Averaged across all discharged events 6.5 - 8.5	TSS ≤ 50 mg/L	Oil and grease present (Y/N)	Comments
1/08/2020	31.15	1	Y	7.6	1.1	N	
2/08/2020	57.33	1	Y	7.2	2	N	
3/08/2020	8.05	1	Y	7.1	1.6	N	
4/08/2020	24.17	1	Y	7.2	2	N	
5/08/2020	25.16	1	Y	7.2	1.9	N	
6/08/2020	19.12	1	Y	7.3	2.1	N	
7/08/2020	43.3	1	Y	7.1	1.5	N	
8/08/2020	51.29	1	Y	7.4	1.6	N	
9/08/2020	25.14	1	Y	7.1	1.7	N	
10/08/2020	39.22	1	Y	7	2.3	N	
11/08/2020	64.42	1	Y	7.2	1.5	N	
12/08/2020	55.39	1	Y	7.1	1.8	N	
13/08/2020	47.32	1	Y	7.2	2.8	N	
14/08/2020	285.25	1	Y	7.4	2.5	N	
15/08/2020	56.5	1	Y	7.6	1.6	N	
16/08/2020	43.31	1	Y	7.3	2.7	N	
17/08/2020	47.39	1	Y	7.8	2	N	
18/08/2020	7.06	1	Y	7.7	1.8	N	

19/08/2020	20.15	1	Y	7.5	0.5	N	
20/08/2020	21.17	1	Y	7.5	0.5	N	
21/08/2020	13.07	1	Y	7.6	2	N	
22/08/2020	29.17	1	Y	7.7	2.2	N	
23/08/2020	31.25	1	Y	7.3	2.5	N	
24/08/2020	14.15	1	Y	7.7	1.3	N	
25/08/2020	19.19	1	Y	7.4	2.38	N	
26/08/2020	366.61	1	Y	7.2	2.5	N	**
27/08/2020	531.24	1	Y	7.5	1.3	N	**
28/08/2020	360.25	1	Y	7.5	2.4	N	**
29/08/2020	149.22	1	Y	7.6	2.4	N	**
30/08/2020	54.47	1	Y	7.5	2.8	N	
31/08/2020	38.32	1	Y	7.3	2.9	N	