

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	Oct-20						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Weblink	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5 (Y/N) averaged across all discharge events	TSS < 50 mg/L (Y/N) averaged across all discharge events	Oil and grease present (Y/N)	Comments
1/10/2020	56.32	1	Y	7.3	0.9	N	
2/10/2020	70.44	1	Y	7.3	0.8	N	
3/10/2020	121.73	1	Y	7.2	0.8	N	
4/10/2020	132.76	1	Y	7.2	0.9	N	
5/10/2020	142.83	1	Y	7.2	0.7	N	
6/10/2020	98.6	1	Y	7.2	0.7	N	
7/10/2020	85.54	1	Y	7.3	0.8	N	
8/10/2020	91.57	1	Y	7.3	0.8	N	
9/10/2020	53.33	1	Y	7.2	1.2	N	
10/10/2020	18.11	1	Y	7.2	1.5	N	
11/10/2020	28.15	1	Y	7	1.6	N	
12/10/2020	83.49	1	Y	7.1	1.5	N	
13/10/2020	43.21	1	Y	7.1	0.8	N	
14/10/2020	40.21	1	Y	7.1	0.7	N	
15/10/2020	39.19	1	Y	7	0.7	N	
16/10/2020	44.22	1	Y	7	1	N	
17/10/2020	34.22	1	Y	7	1.2	N	
18/10/2020	15.08	1	Y	7	0.9	N	
19/10/2020	63.34	1	Y	7.1	0.8	N	
20/10/2020	56.32	1	Y	7.2	0.9	N	
21/10/2020	37.23	1	Y	7.3	0.8	N	
22/10/2020	59.36	1	Y	7.2	1	N	
23/10/2020	77.45	1	Y	7.1	1.2	N	
24/10/2020	61.32	1	Y	7	1.4	N	
25/10/2020	105.59	1	Y	7	1.4	N	
26/10/2020	192.29	1	Y	7	0.9	N	
27/10/2020	82.49	1	Y	7	1.4	N	
28/10/2020	70.4	1	Y	7.7	1.7	N	
29/10/2020	212.12	1	Y	7.1	0.9	N	
30/10/2020	162.84	1	Y	7.1	0.9	N	
31/10/2020	114.6	1	Y	7.1	1	N	