

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	Nov-20						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Weblink	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5  log averaged	TSS < 50 mg/L  averaged	Oil and grease present (Y/N)	Comments
1/11/2020	273.44	1	Y	7.09	0.78	N	No discharge due to maintenance
2/11/2020	139.73	1	Y	7.22	1	N	
3/11/2020	57.3	1	Y	7.3	1.1	N	
4/11/2020	27.15	1	Y	7.28	1.09	N	
5/11/2020	182.97	1	Y	7.23	1.46	N	
6/11/2020	162.85	1	Y	7.31	1.45	N	
7/11/2020	81.43	1	Y	7.39	1.87	N	
8/11/2020	50.24	1	Y	7.3	0.93	N	
9/11/2020	42.23	1	Y	7.35	1.21	N	
10/11/2020	55.33	1	Y	7.35	1.53	N	
11/11/2020	20.1	1	Y	7.45	0.83	N	
12/11/2020	59.24	1	Y	7.37	0.9	N	
13/11/2020	44.2	1	Y	7.37	1.34	N	
14/11/2020	18.07	1	Y	7.41	1.34	N	
15/11/2020	0	NA	NA	NA	NA	NA	
16/11/2020	66.36	1	Y	7.35	0.83	N	
17/11/2020	60.31	1	Y	7.36	0.8	N	
18/11/2020	39.2	1	Y	7.33	0.97	N	
19/11/2020	13.11	1	Y	7.28	1.04	N	
20/11/2020	22.11	1	Y	7.32	0.98	N	
21/11/2020	62.37	1	Y	7.34	10.1	N	
22/11/2020	11.05	1	Y	7.09	0.81	N	
23/11/2020	54.27	1	Y	7.2	1.44	N	
24/11/2020	65.32	1	Y	7.26	0.99	N	
25/11/2020	56.37	1	Y	7.29	0.77	N	
26/11/2020	42.26	1	Y	7.27	0.96	N	
27/11/2020	54.33	1	Y	7.21	0.92	N	
28/11/2020	31.15	1	Y	7.18	0.68	N	
29/11/2020	33.15	1	Y	7.27	0.74	N	
30/11/2020	94.55	1	Y	7.19	1.26	N	