

Water Treatment Plant - Water Discharge Monitoring Data Summary						
Month and Year	Dec-20					
Project	Central Station Main Works					
EPL Licence Number	21148					
EPL Weblink	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge					
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5 log averaged	TSS < 50 mg/L averaged	Oil and grease present (Y/N)
1/12/2020	36.21	1	Y	7.07	1.28	N
2/12/2020	54.31	1	Y	7.08	0.81	N
3/12/2020	22.13	1	Y	7.19	0.66	N
3/12/2020	15.06	2	Y	7.48	0.61	N
4/12/2020	102.32	2	Y	7.23	0.67	N
5/12/2020	35.1	2	Y	7.34	0.76	N
6/12/2020	56.16	2	Y	7.33	0.79	N
7/12/2020	40.12	2	Y	7.25	0.91	N
8/12/2020	31.1	2	Y	7.34	0.86	N
9/12/2020	22.07	2	Y	7.36	0.84	N
9/12/2020	6.02	1	Y	7.44	1.23	N
10/12/2020	55.3	1	Y	7.39	0.72	N
11/12/2020	72.45	1	Y	7.35	0.88	N
12/12/2020	65.37	1	Y	7.32	1.39	N
13/12/2020	31.17	1	Y	7.17	1.21	N
14/12/2020	66.39	1	Y	7.17	1.45	N
15/12/2020	104.55	1	Y	7.12	0.83	N
16/12/2020	178.96	1	Y	7.15	0.86	N
17/12/2020	121.61	1	Y	7.14	1.43	N
18/12/2020	75.45	1	Y	7.21	1.49	N
19/12/2020	68.48	1	Y	7.17	1.58	N
20/12/2020	92.6	1	Y	7.05	0.94	N
21/12/2020	99.61	1	Y	7.05	0.79	N
22/12/2020	248.7	1	Y	7.08	0.86	N
23/12/2020	185.08	1	Y	7.09	0.98	N
24/12/2020	82.45	1	Y	7.12	1.5	N
25/12/2020	32.18	1	Y	7.22	0.93	N
26/12/2020	123.7	1	Y	7.19	0.81	N
27/12/2020	69.48	1	Y	7.11	0.97	N
28/12/2020	102.66	1	Y	7.14	0.57	N
29/12/2020	145.85	1	Y	7.22	0.82	N
30/12/2020	288.69	1	Y	7.21	0.67	N
31/12/2020	43.25	1	Y	7.24	0.89	N