

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	Jan-21						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Weblink	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5 log averaged	TSS < 50 mg/L averaged	Oil and grease present (Y/N)	Comments
1/01/2021	135.74	1	Y	7.24	0.95	N	
2/01/2021	62.31	1	Y	7.2	1.04	N	
3/01/2021	144.82	1	Y	7.25	1.28	N	
4/01/2021	19.11	1	Y	7.22	1.6	N	
4/01/2021	162.62	2	Y	7.21	1.19	N	
5/01/2021	123.3	2	Y	7.26	1.26	N	
6/01/2021	143.4	2	Y	7.26	0.94	N	
7/01/2021	120.35	2	Y	7.25	1.29	N	
8/01/2021	101.26	2	Y	7.24	0.64	N	
9/01/2021	61.18	2	Y	7.31	0.88	N	
10/01/2021	37.1	2	Y	7.38	0.46	N	
11/01/2021	76.27	2	Y	7.33	0.55	N	
12/01/2021	127.35	2	Y	7.29	0.87	N	
13/01/2021	68.22	2	Y	7.25	0.57	N	
14/01/2021	156.41	2	Y	7.26	1.33	N	
15/01/2021	94.26	2	Y	7.36	1.08	N	
16/01/2021	41.12	2	Y	7.36	1.64	N	
17/01/2021	22.07	2	Y	7.29	0.78	N	
18/01/2021	91.27	2	Y	7.38	0.85	N	
19/01/2021	92.25	2	Y	7.22	1.32	N	
20/01/2021	88.22	2	Y	7.22	0.68	N	
21/01/2021	133.35	2	Y	7.27	1.18	N	
22/01/2021	95.28	2	Y	7.32	1.25	N	
23/01/2021	23.07	2	Y	7.24	0.65	N	
24/01/2021	13.04	2	Y	7.25	0.61	N	
25/01/2021	80.22	2	Y	7.28	0.96	N	
26/01/2021	21.04	2	Y	7.23	0.26	N	
27/01/2021	157.43	2	Y	7.19	0.89	N	
28/01/2021	122.34	2	Y	7.23	0.75	N	
29/01/2021	119.33	2	Y	7.35	0.76	N	
30/01/2021	138.42	2	Y	7.33	0.85	N	
31/01/2021	51.13	2	Y	7.58	1.1	N	
Total for the month:	2,923.28						