

Water Treatment Plant - Water Discharge Monitoring Data Summary							
Month and Year	Mar-21						
Project	Central Station Main Works						
EPL Licence Number	21148						
EPL Weblink	https://centralstationmetro.com/documents/						
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge						
Date	Volume of discharge (KL)	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5 log averaged	TSS < 50 mg/L averaged	Oil and grease present (Y/N)	Comments
1/03/2021	193.97	1	Y	7.22	1.35	N	
2/03/2021	143.86	1	Y	7.23	1.26	N	
3/03/2021	117.69	1	Y	7.24	1.81	N	
4/03/2021	112.72	1	Y	7.23	1.39	N	
5/03/2021	106.51	1	Y	7.24	1.55	N	
6/03/2021	148.74	1	Y	7.28	1.97	N	
7/03/2021	107.57	1	Y	7.27	1.39	N	
8/03/2021	136.8	1	Y	7.23	1.74	N	
9/03/2021	76.46	1	Y	7.24	1.75	N	
10/03/2021	95.52	1	Y	7.27	1.75	N	
11/03/2021	101.49	1	Y	7.32	1.53	N	
12/03/2021	164.94	1	Y	7.37	1.22	N	
13/03/2021	129.83	1	Y	7.38	1.66	N	
14/03/2021	231.17	1	Y	7.37	1	N	
15/03/2021	182.99	1	Y	7.39	1.68	N	
16/03/2021	184.15	1	Y	7.43	1.29	N	
17/03/2021	148.85	1	Y	7.42	1.6	N	
18/03/2021	431.73	1	Y	7.39	0.94	N	
19/03/2021	531.48	1	Y	7.4	1.24	N	
20/03/2021	256.82	1	Y	7.42	0.77	N	
21/03/2021	375.48	1	Y	7.39	0.73	N	
22/03/2021	514.48	1	Y	7.39	0.94	N	
23/03/2021	414.82	1	Y	7.41	0.81	N	
24/03/2021	320.12	1	Y	7.45	1.53	N	
25/03/2021	228.49	1	Y	7.45	1.31	N	
26/03/2021	158.08	1	Y	7.4	1.49	N	
27/03/2021	58.4	1	Y	7.43	1.35	N	
28/03/2021	115.74	1	Y	7.43	1.48	N	
29/03/2021	132.69	1	Y	7.39	1.55	N	
30/03/2021	109.52	1	Y	7.4	1.21	N	
31/03/2021	191.9	1	Y	7.4	1.44	N	
Total for the month:	6,223.01						