	Water Treatment Plant - Water Discharge Monitoring Data Summary								
Month and Year	**Jul-21**								
Project	**Central Station Main Works**								
EPL Licence Number	**21148**								
EPL Weblink	https://centralstationmetro.com/documents/								
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**								
Date	**Volume of discharge (KL)**	**Discharge Point 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5** log averaged	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L** averaged	**Oil and grease present (Y/N)**	**Comments**
1/07/2021	83.47	1	Y	7.30	7.70	6.98	1.14	N	
2/07/2021	57.3	1	Y	7.24	7.75	6.95	0.94	N	
3/07/2021	74.43	1	Y	7.36	7.74	6.94	1.17	N	
4/07/2021	28.16	1	Y	7.37	7.71	7.06	1.12	N	
5/07/2021	44.25	1	Y	7.26	7.64	6.98	1.50	N	
6/07/2021	87.39	1	Y	7.24	7.65	6.94	1.43	N	
7/07/2021	104.54	1	Y	7.26	7.73	6.94	1.23	N	
8/07/2021	64.42	1	Y	7.26	7.66	6.93	1.16	N	
9/07/2021	75.5	1	Y	7.25	7.52	6.99	1.24	N	
10/07/2021	76.46	1	Y	7.27	7.58	6.99	1.34	N	
11/07/2021	77.4	1	Y	7.25	7.73	6.99	5.09	N	
12/07/2021	173.18	1	Y	7.26	7.52	7.03	1.57	N	
13/07/2021	109.59	1	Y	7.27	7.51	7.02	1.37	N	
14/07/2021	58.35	1	Y	7.29	7.50	7.03	1.32	N	
15/07/2021	78.48	1	Y	7.27	7.55	7.00	1.44	N	
16/07/2021	71.38	1	Y	7.25	7.75	6.90	1.85	N	
17/07/2021	69.41	1	Y	7.26	7.74	6.90	1.66	N	
18/07/2021	106.57	1	Y	7.35	7.86	6.93	1.70	N	
19/07/2021	64.37	1	Y	7.30	7.79	6.93	1.52	N	
20/07/2021	37.22	1	Y	7.29	7.65	6.96	1.39	N	
21/07/2021	42.21	1	Y	7.29	7.90	6.92	1.29	N	
22/07/2021	46.25	1	Y	7.31	7.73	6.94	1.54	N	
23/07/2021	81.48	1	Y	7.31	8.00	6.92	1.34	N	
24/07/2021	51.32	1	Y	7.34	7.80	6.92	1.19	N	
25/07/2021	45.25	1	Y	7.27	7.60	6.93	1.35	N	
26/07/2021	92.5	1	Y	7.29	7.71	6.91	1.07	N	
27/07/2021	107.63	1	Y	7.33	7.61	6.92	1.18	N	
28/07/2021	133.75	1	Y	7.32	7.84	6.90	1.42	N	
29/07/2021	41.23	1	Y	7.38	7.64	7.01	1.38	N	
30/07/2021	65.41	1		7.27	7.63	6.90	1.98	N	
31/07/2021	44.28	1	Y	7.4	7.65	6.95	1.83	N	
Total for the month:	2,293.18								