	Water Treatment Plant - Water Discharge Monitoring Data Summary								
Month and Year	**Aug-21**								
Project	**Central Station Main Works**								
EPL Licence Number	**21148**								
EPL Weblink	https://centralstationmetro.com/documents/								
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**								
Date	**Volume of discharge (KL)**	**Discharge Point 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Oil and grease present (Y/N)**	**Comments**
1/08/2021	60.37	1	Y	7.43	7.64	7.00	1.81	N	
2/08/2021	70.46	1	Y	7.31	7.59	6.91	1.41	N	
3/08/2021	61.41	1	Y	7.4	7.61	7.01	1.37	N	
4/08/2021	27.18	1	Y	7.25	7.54	6.96	1.85	N	
5/08/2021	66.43	1	Y	7.3	7.61	6.91	1.72	N	
6/08/2021	27.18	1	Y	7.22	7.43	6.92	1.76	N	
7/08/2021	9.04	1	Y	7.22	7.40	7.06	1.84	N	
8/08/2021	7.04	1	Y	7.27	7.44	6.99	1.36	N	
9/08/2021	89.55	1	Y	7.24	7.46	6.93	1.45	N	
10/08/2021	70.41	1	Y	7.23	7.44	6.92	1.52	N	
11/08/2021	14.09	1	Y	7.25	7.65	6.91	2.18	N	
12/08/2021	0	NA	Y	NA	NA	NA	NA	N	No discharge today.
13/08/2021	73.41	1	Y	7.26	7.68	6.93	2.28	N	
14/08/2021	145.92	1	Y	7.25	7.75	6.90	2.31	N	
15/08/2021	56.37	1	Y	7.27	7.66	6.93	2.28	N	
16/08/2021	24.16	1	Y	7.28	7.56	6.90	2.27	N	
17/08/2021	18.09	1	Y	7.19	7.48	6.94	2.54	N	
18/08/2021	0	NA	Y	NA	NA	NA	NA	N	No discharge today.
19/08/2021	10.06	1	Y	7.29	7.73	7.04	3.16	N	
20/08/2021	27.16	1	Y	7.29	7.75	6.91	1.83	N	
21/08/2021	0	NA	Y	NA	NA	NA	NA	N	No discharge today.
22/08/2021	0	NA	Y	NA	NA	NA	NA	N	No discharge today.
23/08/2021	21.16	1	Y	7.29	7.59	6.99	1.8	N	
24/08/2021	448.7	1	Y	7.22	7.87	6.87	1.48	N	
25/08/2021	461.61	1	Y	7.27	7.95	6.90	1.49	N	
26/08/2021	249.51	1	Y	7.29	7.85	6.89	1.79	N	
27/08/2021	158.99	1	Y	7.29	7.89	6.87	2.4	N	
28/08/2021	186.09	1	Y	7.3	7.91	6.91	2	N	
29/08/2021	117.7	1	Y	7.37	7.79	6.91	2.04	N	
30/08/2021	53.34	1	Y	7.36	7.83	6.91	2.16	N	
31/08/2021	107.67	1	Y	7.36	8.02	6.89	1.52	N	
Total for the month:	2,663.10								