	Water Treatment Plant - Water Discharge Monitoring Data Summary								
Month and Year	**Nov-21**								
Project	**Central Station Main Works**								
EPL Licence Number	**21148**								
EPL Weblink	https://centralstationmetro.com/documents/								
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**								
Date	**Volume of discharge (KL)**	**Discharge Point 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L / NTU < 10 (*) averaged**	**Oil and grease present (Y/N)**	**Comments**
1/11/2021	38.22	1	Y	7.32	7.80	6.90	2.08	N	
1/11/2021		2	Y	7.85	8.16	7.26	2.67 NTU	N	WTP2 data
2/11/2021	28.18	1	Y	7.31	7.76	6.88	2.39	N	
2/11/2021		2	Y	7.01	7.65	6.57	2.72 NTU	N	WTP2 data
3/11/2021	37.21	1	Y	7.26	7.77	6.93	2.25	N	
3/11/2021		2	Y	7.43	8.14	6.97	3.38 NTU	N	WTP2 data
4/11/2021	29.18	1	Y	7.24	7.86	6.91	1.85	N	
4/11/2021		2	Y	7.36	7.41	7.22	4.98 NTU	N	WTP2 data
5/11/2021	66.36	1	Y	7.2	7.81	6.91	1.81	N	
5/11/2021		2	Y	6.91	6.99	6.85	2.47 NTU	N	WTP2 data
6/11/2021	71.41	1	Y	7.23	8.42	6.90	2	N	
6/11/2021		2	Y	6.76	6.76	6.76	4.64 NTU	N	WTP2 data
7/11/2021	32.13	1	Y	7.22	7.60	6.91	1.8	N	
7/11/2021		2	Y	6.93	6.99	6.79	6.87 NTU	N	WTP2 data
8/11/2021	91.5	1	Y	7.23	8.04	6.86	1.46	N	
8/11/2021		2	Y	6.93	7.05	6.82	3.95 NTU	N	WTP2 data
9/11/2021	72.43	1	Y	7.29	7.87	6.89	1.94	N	
9/11/2021		2	Y	6.88	6.93	6.82	3.64 NTU	N	WTP2 data
10/11/2021	94.55	1	Y	7.24	7.79	6.89	1.29	N	
10/11/2021		2	Y	7.04	7.43	6.90	4.23 NTU	N	WTP2 data
11/11/2021	59.3	1	Y	7.32	7.92	6.92	1.65	N	
11/11/2021		2	Y	7.45	7.58	6.71	0 NTU	N	WTP2 data
12/11/2021	72.41	1	Y	7.28	7.82	6.89	1.69	N	
12/11/2021		2	Y	7.2	7.49	6.65	2.63 NTU	N	WTP2 data
13/11/2021	45.24	1	Y	7.34	7.89	6.92	2.53	N	
13/11/2021		2	Y	6.75	7.33	6.55	5.43 NTU	N	WTP2 data
14/11/2021	34.18	1	Y	7.28	7.69	6.89	2.02	N	
14/11/2021		2	Y	6.84	6.90	6.78	8.16 NTU	N	WTP2 data
15/11/2021	158.95	1	Y	7.34	8.05	6.88	2.14	N	
15/11/2021		2	Y	7.22	8.17	6.65	1.16 NTU	N	WTP2 data
16/11/2021	114.69	1	Y	7.34	7.95	6.89	2.21	N	
16/11/2021	0	2	Y	N/A	N/A	N/A	N/A	N	WTP2 data, no discharge
17/11/2021	113.61	1	Y	7.26	7.83	6.88	2.26	N	
17/11/2021		2	Y	7.13	7.28	6.69	1.45 NTU	N	WTP2 data
18/11/2021	10.05	1	Y	7.35	7.75	6.91	2.88	N	
18/11/2021		2	Y	7.13	7.53	7.01	3.58 NTU	N	WTP2 data
19/11/2021	23.11	1	Y	7.28	7.69	6.92	1.99	N	
19/11/2021		2	Y	6.94	7.37	6.63	3.52 NTU	N	WTP2 data
20/11/2021	98.47	1	Y	7.3	7.98	6.91	1.81	N	
20/11/2021		2	Y	6.95	7.19	6.61	0.01 NTU	N	WTP2 data
21/11/2021	63.31	1	Y	7.39	7.93	6.92	1.3	N	
21/11/2021		2	Y	6.77	6.90	6.57	0.49 NTU	N	WTP2 data
22/11/2021	134.62	1	Y	7.4	8.00	6.87	1.66	N	
22/11/2021		2	Y	6.8	6.96	6.77	0 NTU	N	WTP2 data
23/11/2021	167.71	1	Y	7.43	8.05	6.89	1.84	N	
23/11/2021		2	Y	6.96	7.48	6.77	0.15 NTU	N	WTP2 data
24/11/2021	64.29	1	Y	7.43	7.90	6.93	2.07	N	
24/11/2021		2	Y	6.75	6.99	6.52	2.13 NTU	N	WTP2 data
25/11/2021	141.63	1	Y	7.44	8.09	6.88	1.71	N	
25/11/2021	0	2	Y	N/A	N/A	N/A	N/A	N	WTP2 data; no discharge
26/11/2021	268.59	1	Y	7.4	8.07	6.84	1.39	N	
26/11/2021		2	Y	7.24	8.34	6.97	3.68 NTU	N	WTP2 data
27/11/2021	165.86	1	Y	7.43	8.06	6.83	1.8	N	
27/11/2021		2	Y	7.2	7.38	7.06	3.48 NTU	N	WTP2 data
28/11/2021	77.42	1	Y	7.49	8.02	6.80	2.37	N	
28/11/2021	0	2	Y	N/A	N/A	N/A	N/A	N	WTP2 data; no discharge
29/11/2021	77.42	1	Y	7.44	8.08	6.91	2.18	N	
29/11/2021		2	Y	7.42	7.67	7.31	0.11 NTU	N	WTP2 data
30/11/2021	75.48	1	Y	7.42	7.94	6.88	3.02	N	
30/11/2021	1017.94	2	Y	7.07	7.40	6.75	1.4 NTU	N	WTP2 data
Total for the month:	3,545.45								