	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Dec-21**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/12/2021	91.56	1	Y	7.45	7.96	6.87	2.27	4.43	1.30	N	
1/12/2021		2	Y	7.07	7.18	6.91	11.43	14.2	9	N	WTP2 data
2/12/2021	69.39	1	Y	7.51	7.91	6.90	2.39	4.16	1.11	N	
2/12/2021		2	Y	6.97	7.45	6.59	7.50	14.66	6.26	N	WTP2 data
3/12/2021	48.26	1	Y	7.39	7.74	6.90	2.41	3.51	0.92	N	
3/12/2021		2	Y	7.35	7.57	6.75	7.55	8.74	6.26	N	WTP2 data
4/12/2021	70.41	1	Y	7.45	7.96	6.87	2.93	5.09	1.34	N	
4/12/2021		2	Y	7.03	7.15	6.83	8.74	15.78	8.04	N	WTP2 data
5/12/2021	59.29	1	Y	7.44	7.97	6.92	2.14	4.06	0.86	N	
5/12/2021		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
6/12/2021	57.29	1	Y	7.48	7.98	6.95	2.28	3.91	1.28	N	
6/12/2021		2	Y	7.32	7.74	7.13	7.79	8.36	6.26	N	WTP2 data
7/12/2021	66.38	1	Y	7.52	7.98	6.87	2.06	3.41	0.97	N	
7/12/2021		2	Y	7.44	7.62	7.07	8.68	11.08	7.74	N	WTP2 data
8/12/2021	68.42	1	Y	7.46	7.92	6.89	2.07	3.24	0.90	N	
8/12/2021		2	Y	7.06	7.24	6.62	11.82	15.15	9.72	N	WTP2 data
9/12/2021	77.41	1	Y	7.5	7.96	6.88	1.72	3.24	0.44	N	
9/12/2021		2	Y	6.88	6.95	6.74	8.94	12.93	7.24	N	WTP2 data
10/12/2021	207.28	1	Y	7.39	7.98	6.91	1.55	4.23	0.23	N	
10/12/2021		2	Y	6.76	7.05	6.56	9.77	14.92	6.26	N	WTP2 data
11/12/2021	159.84	1	Y	7.41	7.97	6.89	2.51	4.73	0.82	N	
11/12/2021		2	Y	6.67	6.71	6.60	6.26	6.26	6.26	N	WTP2 data
12/12/2021	89.56	1	Y	7.42	7.92	6.89	2.43	4.77	0.71	N	
12/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
13/12/2021	77.56	1	Y	7.46	7.98	6.88	3.14	5.26	1.47	N	
13/12/2021		2	Y	6.79	6.90	6.69	7.33	9.88	6.26	N	WTP2 data
14/12/2021	90.63	1	Y	7.45	8.07	6.98	3.52	5.47	1.43	N	
14/12/2021		2	Y	6.87	7.08	6.51	8.46	11.32	6.26	N	WTP2 data
15/12/2021	60.43	1	Y	7.46	7.97	6.91	2.5	4.96	0.99	N	
15/12/2021		2	Y	7.03	7.21	6.63	6.95	9.07	6.26	N	WTP2 data
16/12/2021	65.41	1	Y	7.52	7.97	7.01	2.68	4.23	1.54	N	
16/12/2021		2	Y	7.31	7.99	7.12	6.92	9.07	6.26	N	WTP2 data
17/12/2021	137.85	1	Y	7.41	8.02	6.97	3.59	5.59	1.43	N	
17/12/2021		2	Y	6.74	7.42	6.57	6.82	8.47	6.26	N	WTP2 data
18/12/2021	80.51	1	Y	7.48	7.92	6.91	3.48	5.63	1.72	N	
18/12/2021		2	Y	6.72	6.85	6.58	8.79	11.21	7.42	N	WTP2 data
19/12/2021	61.34	1	Y	7.47	8.04	6.91	3.52	4.92	1.89	N	
19/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
20/12/2021	47.27	1	Y	7.49	8.03	6.94	3.32	4.58	1.89	N	
20/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
21/12/2021	92.61	1	Y	7.4	7.96	6.59	2.98	4.67	1.53	N	
21/12/2021		2	Y	7.91	8.16	7.54	6.26	6.26	6.26	N	WTP2 data
22/12/2021	99.63	1	Y	7.42	7.96	6.93	3.41	5.42	1.60	N	
22/12/2021		2	Y	8.28	8.34	8.16	6.30	6.85	6.26	N	WTP2 data
23/12/2021	155.95	1	Y	7.45	8.00	6.90	2.84	4.60	1.54	N	
23/12/2021		2	Y	8.34	8.37	8.31	6.91	8.00	6.26	N	WTP2 data
24/12/2021	115.75	1	Y	7.41	8.08	6.89	3.17	5.57	1.32	N	
24/12/2021		2	Y	8.27	8.31	8.22	7.65	8.69	6.39	N	WTP2 data
25/12/2021	66.38	1	Y	7.51	8.06	6.93	3.40	4.52	2.12	N	
25/12/2021		2	Y	8.29	8.38	8.27	7.60	9.43	6.40	N	WTP2 data
26/12/2021	92.54	1	Y	7.54	8.04	6.95	3.43	4.62	1.64	N	
26/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
27/12/2021	78.48	1	Y	7.51	8.10	6.97	2.81	4.43	0.95	N	
27/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
28/12/2021	159.93	1	Y	7.44	7.92	6.91	2.56	4.35	0.78	N	
28/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
29/12/2021	117.71	1	Y	7.48	7.98	6.91	2.73	4.25	1.37	N	
29/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
30/12/2021	90.54	1	Y	7.45	7.94	6.91	3.03	4.84	1.83	N	
30/12/2021	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
31/12/2021	31.2	1	Y	7.55	8.02	7.09	3.35	4.60	2.46	N	
31/12/2021	427.35	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
Total for the month:	3,214.16										