	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Jan-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/01/2022	0	1	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No discharge
1/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data, no discharge
2/01/2022	0	1	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No discharge
2/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data, no discharge
3/01/2022	0	1	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No discharge
3/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data, no discharge
4/01/2022	14.07	1	Y	7.47	8.05	7.10	2.74	4.02	2.00	N	
4/01/2022		2	Y	7.95	8.21	7.13	6.27	6.77	6.26	N	WTP2 data
5/01/2022	61.35	1	Y	7.44	7.88	6.92	3.41	5.25	1.37	N	
5/01/2022		2	Y	8.13	8.25	7.26	6.35	6.90	6.26	N	WTP2 data
6/01/2022	125.78	1	Y	7.49	7.98	6.93	3.99	5.95	2.00	N	
6/01/2022		2	Y	8.14	8.14	8.14	7.11	7.11	7.11	N	WTP2 data
7/01/2022	79.46	1	Y	7.54	8.08	6.95	3.8	5.55	1.62	N	
7/01/2022		2	Y	7.28	7.72	6.87	9.6	14.22	7.23	N	WTP2 data
8/01/2022	221.3	1	Y	7.45	8.08	6.91	3.02	5.13	0.88	N	
8/01/2022		2	Y	7.09	7.18	6.97	9.25	12.18	6.44	N	WTP2 data
9/01/2022	138.91	1	Y	7.34	8.06	6.88	3.47	5.63	1.53	N	
9/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
10/01/2022	81.49	1	Y	7.34	7.93	6.90	3.19	5.34	1.79	N	
10/01/2022		2	Y	7.86	8.02	7.52	8.58	9.74	6.26	N	WTP2 data
11/01/2022	69.37	1	Y	7.53	8.12	6.89	3.4	5.95	1.09	N	
11/01/2022		2	Y	7.71	8.02	6.98	9.50	15.80	6.59	N	WTP2 data
12/01/2022	81.52	1	Y	7.53	8.14	6.92	2.37	4.56	0.63	N	
12/01/2022		2	Y	7.25	7.70	6.80	6.99	12.47	6.26	N	WTP2 data
13/01/2022	288.58	1	Y	7.55	8.11	6.88	2.06	3.93	0.57	N	
13/01/2022		2	Y	7.37	7.63	7.18	10.18	13.37	8.93	N	WTP2 data
14/01/2022	208.18	1	Y	7.55	8.11	6.95	2.75	6.05	0.53	N	
14/01/2022		2	Y	7.15	7.80	6.59	10.6	15.43	7.14	N	WTP2 data
15/01/2022	123.71	1	Y	7.56	8.08	7.03	3.62	5.36	1.28	N	
15/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
16/01/2022	89.51	1	Y	7.53	8.06	7.11	4.18	5.59	2.21	N	
16/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
17/01/2022	61.36	1	Y	7.52	8.08	6.96	3.95	5.38	1.74	N	
17/01/2022		2	Y	7.44	7.85	6.53	6.26	6.26	6.26	N	WTP2 data
18/01/2022	73.44	1	Y	7.57	8.11	6.98	1.73	5.05	0.13	N	
18/01/2022		2	Y	7.23	7.79	6.83	7	8.79	6.26	N	WTP2 data
19/01/2022	34.23	1	Y	7.51	8.04	6.96	2.12	3.59	0.23	N	
19/01/2022		2	Y	7.43	7.78	6.62	10.05	13.50	8.00	N	WTP2 data
20/01/2022	112.74	1	Y	7.52	8.07	6.97	2.56	4.58	0.95	N	
20/01/2022		2	Y	7.27	7.38	7.19	6.31	6.42	6.26	N	WTP2 data
21/01/2022	54.34	1	Y	7.49	7.96	7.02	2.73	4.71	1.13	N	
21/01/2022		2	Y	7.37	7.64	7.12	6.74	7.82	6.26	N	WTP2 data
22/01/2022	28.2	1	Y	7.58	7.96	7.16	3.41	5.07	2.00	N	
22/01/2022		2	Y	7.58	7.70	7.43	6.6	7.29	6.26	N	WTP2 data
23/01/2022	22.1	1	Y	7.47	7.75	7.04	2.49	3.81	0.86	N	
23/01/2022		2	Y	7.44	7.54	7.36	7.23	8.71	6.26	N	WTP2 data
24/01/2022	78.39	1	Y	7.43	7.98	6.93	2.04	5.19	0.61	N	
24/01/2022		2	Y	7.17	7.47	6.83	11.02	15.29	6.26	N	WTP2 data
25/01/2022	28.21	1	Y	7.48	8.04	7.02	3.19	5.23	1.34	N	
25/01/2022		2	Y	6.97	7.23	6.81	9.02	15.31	7.03	N	WTP2 data
26/01/2022	0	1	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No discharge
26/01/2022		2	Y	7.11	7.41	7.00	6.99	8.15	6.26	N	WTP2 data
27/01/2022	25.19	1	Y	7.68	8.05	7.18	4.6	5.42	3.07	N	
27/01/2022		2	Y	7.05	7.23	6.87	7.45	8.79	6.26	N	WTP2 data
28/01/2022	88.45	1	Y	7.61	8.10	6.88	2.8	4.77	1.13	N	
28/01/2022		2	Y	6.77	7.19	6.64	11.49	14.60	10.60	N	WTP2 data
29/01/2022	57.29	1	Y	7.56	7.98	7.06	2.54	3.89	0.78	N	
29/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
30/01/2022	34.18	1	Y	7.64	7.96	7.08	2.78	3.78	1.98	N	
30/01/2022	0	2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data; no discharge
31/01/2022	78.45	1	Y	7.68	8.03	6.86	2.42	3.85	1.07	N	
31/01/2022	1127.54	2	Y	7.61	7.84	7.41	9.9	14.50	6.75	N	WTP2 data
Total for the month:	3,487.34										