	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Apr-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/04/2022		2	Y	7.38	8.02	6.93	6.8	24.64	6.26	N	WTP2 data
2/04/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - Shut off for Maintenance
3/04/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - Shut off for Maintenance
4/04/2022		2	Y	7.59	7.78	7.43	17.01	18.71	16.04	N	WTP2 data
5/04/2022		2	Y	7.66	7.78	7.43	25.7	34.05	16.04	N	WTP2 data
6/04/2022		2	Y	7.67	7.74	7.21	20.83	27.14	10.11	N	WTP2 data
7/04/2022		2	Y	7.72	7.90	7.50	22.05	37.28	6.26	N	WTP2 data
8/04/2022		2	Y	7.39	7.47	7.29	29.86	35.04	26.25	N	WTP2 data
9/04/2022		2	Y	7.47	7.55	7.28	23.54	27.05	20.25	N	WTP2 data
10/04/2022		2	Y	7.59	7.65	7.53	21.31	23.75	18.26	N	WTP2 data
11/04/2022		2	Y	7.68	7.81	7.62	19.62	21.40	17.30	N	WTP2 data
12/04/2022		2	Y	7.82	7.88	7.75	19.25	20.31	17.77	N	WTP2 data
13/04/2022		2	Y	7.95	8.07	7.88	19.45	20.34	18.22	N	WTP2 data
14/04/2022		2	Y	7.05	7.10	6.92	18.1	6.26	39.25	N	WTP2 data
15/04/2022		2	Y	7.16	7.21	7.09	26.57	19.83	32.99	N	WTP2 data
16/04/2022		2	Y	7.27	7.33	7.21	21.89	17.58	26.08	N	WTP2 data
17/04/2022		2	Y	7.39	7.32	7.44	20.28	22.53	17.00	N	WTP2 data
18/04/2022		2	Y	7.52	7.62	7.43	18.52	20.60	16.36	N	WTP2 data
19/04/2022		2	Y	7.64	7.74	7.55	17.84	19.38	16.11	N	WTP2 data
20/04/2022		2	Y	7.72	7.78	7.69	18.23	40.50	6.26	N	WTP2 data
21/04/2022		2	Y	7.75	7.70	7.82	34.32	40.50	28.62	N	WTP2 data
22/04/2022		2	Y	7.96	8.06	7.76	23.79	22.01	31.67	N	WTP2 data
23/04/2022		2	Y	8.02	8.09	7.92	19.48	22.17	17.16	N	WTP2 data
24/04/2022		2	Y	8.01	8.05	7.93	17.52	18.71	16.04	N	WTP2 data
25/04/2022		2	Y	8.05	8.09	8.00	16.68	17.65	15.14	N	WTP2 data
26/04/2022		2	Y	8.09	8.16	8.04	15.79	16.74	14.47	N	WTP2 data
27/04/2022		2	Y	8.03	8.12	6.88	14.6	15.23	10.27	N	WTP2 data
28/04/2022		2	Y	7.42	7.88	6.91	22.05	38.50	6.26	N	WTP2 data
29/04/2022		2	Y	7.27	7.52	6.89	6.52	6.93	6.26	N	WTP2 data
30/04/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
Total for the month:	184.85										