	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Feb-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/02/2022		1	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No discharge
1/02/2022		2	Y	7.78	7.85	7.72	9.77	14.63	7.18	N	WTP2 data
2/02/2022		1	Y	7.55	8.16	6.93	1.85	30.79	0.36	N	Final discharge prior to decomissioning
2/02/2022		2	Y	7.98	8.34	7.78	6.78	10.00	6.26	N	WTP2 data
3/02/2022		2	Y	7.09	7.82	6.52	6.26	6.26	6.26	N	WTP2 data
4/02/2022		2	Y	7.29	8.26	6.82	6.26	6.26	6.26	N	WTP2 data
5/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
6/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
7/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
8/02/2022		2	Y	7.95	8.02	7.87	6.26	6.26	6.26	N	WTP2 data - Shut off for Maintenance
9/02/2022		2	Y	7.76	8.32	7.11	6.26	6.26	6.26	N	WTP2 data
10/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
11/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
12/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
13/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
14/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
15/02/2022		2	Y	6.88	7.39	6.62	15.9	22.24	6.26	N	WTP2 data
16/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
17/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
18/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
19/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
20/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
21/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
22/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
23/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
24/02/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shut off for Maintenance
25/02/2022		2	Y	7.14	7.77	6.60	6.26	6.26	6.26	N	WTP2 data
26/02/2022		2	Y	7.91	8.32	7.04	6.26	6.26	6.26	N	WTP2 data
27/02/2022		2	Y	7.77	7.92	7.84	6.26	6.26	6.26	N	WTP2 data
28/02/2022	120.68	2	Y	7.23	8.11	6.50	18.08	27.11	6.26	N	WTP2 data
Total for the month:	120.68										