	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Mar-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/03/2022		2	Y	7.34	7.37	7.15	19.86	21.85	17.56	N	WTP2 data
2/03/2022		2	Y	7.53	7.82	7.24	27.80	34.81	20.79	N	WTP2 data
3/03/2022		2	Y	7.5	7.64	7.43	6.26	6.26	6.26	N	WTP2 data
4/03/2022		2	Y	7.57	8.32	6.53	13.31	18.87	6.26	N	WTP2 data
5/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
6/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
7/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
8/03/2022		2	Y	7.33	7.61	6.64	7.37	36.19	6.26	N	WTP2 data
9/03/2022		2	Y	7.69	7.74	7.60	6.26	6.26	6.26	N	WTP2 data
10/03/2022		2	Y	7.73	7.76	7.66	6.26	6.26	6.26	N	WTP2 data
11/03/2022		2	Y	7.75	7.78	7.69	6.26	6.26	6.26	N	WTP2 data
12/03/2022		2	Y	7.76	7.81	7.71	6.26	6.26	6.26	N	WTP2 data
13/03/2022		2	Y	7.74	7.79	7.62	6.26	6.26	6.26	N	WTP2 data
14/03/2022		2	Y	7.72	7.79	7.53	6.26	6.26	6.26	N	WTP2 data
15/03/2022		2	Y	7.71	7.79	7.41	6.26	6.26	6.26	N	WTP2 data
16/03/2022		2	Y	7.61	7.88	6.68	6.26	6.26	6.26	N	WTP2 data
17/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
18/03/2022		2	Y	7.1	8.49	6.50	6.26	6.26	6.26	N	WTP2 data
19/03/2022		2	Y	7.44	7.96	6.58	6.26	6.26	6.26	N	WTP2 data
20/03/2022		2	Y	6.85	7.14	6.62	6.26	6.26	6.26	N	WTP2 data
21/03/2022		2	Y	6.75	6.82	6.68	6.26	6.26	6.26	N	WTP2 data
22/03/2022		2	Y	7.42	8.34	6.82	6.26	6.26	6.26	N	WTP2 data
23/03/2022		2	Y	7.72	7.81	7.66	6.26	6.26	6.26	N	WTP2 data
24/03/2022		2	Y	7.7	7.87	7.61	6.26	6.26	6.26	N	WTP2 data
25/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - Shutdown for maintenance
26/03/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N	WTP2 data - No discharge
27/03/2022		2	Y	7.82	7.51	7.41	6.26	6.26	6.26	N	WTP2 data
28/03/2022		2	Y	7.71	7.83	7.41	6.89	30.39	6.26	N	WTP2 data
29/03/2022		2	Y	7.43	7.95	6.78	10.49	35.98	6.26	N	WTP2 data
30/03/2022		2	Y	7.63	7.82	7.12	7.98	32.12	6.26	N	WTP2 data
31/03/2022		2	Y	7.02	7.81	6.64	6.26	6.26	6.26	N	WTP2 data
	325.52										
Total for the month:	325.52										