	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Jul-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/07/2022		2	Y	6.81	6.95	6.69	25.95	38.67	9.32	N	WTP2 data
2/07/2022		2	Y	7.02	7.33	6.58	28.2	39.4	14.83	N	WTP2 data
3/07/2022		2	Y	7.47	7.84	7.03	14.96	16.44	13.64	N	WTP2 data
4/07/2022		2	Y	7.41	7.79	6.96	25.1	36.16	14.84	N	WTP2 data
5/07/2022		2	Y	7.2	7.66	6.62	15.57	23.08	5.72	N	WTP2 data
6/07/2022		2	Y	7.1	7.47	6.9	25.76	38.44	9.95	N	WTP2 data
7/07/2022		2	Y	7.22	7.72	6.74	10.96	31.77	6.26	N	WTP2 data
8/07/2022		2	Y	7.34	7.35	7.33	9.08	9.25	8.9	N	WTP2 data
9/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
10/07/2022		2	Y	7.51	7.55	7.48	11.4	11.55	11.24	N	WTP2 data
11/07/2022		2	Y	7.26	7.61	6.85	17.56	25.74	11.96	N	WTP2 data
12/07/2022		2	Y	7.67	7.67	7.67	17.45	17.45	17.45	N	WTP2 data
13/07/2022		2	Y	6.91	6.94	6.89	11.92	14.08	8.42	N	WTP2 data
14/07/2022		2	Y	7.08	7.25	6.94	16.64	29.29	8.42	N	WTP2 data
15/07/2022		2	Y	7.19	7.26	7.13	6.26	6.26	6.26	N	WTP2 data
16/07/2022		2	Y	7.25	7.25	7.24	13.41	16.25	10.56	N	WTP2 data
17/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
18/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
19/07/2022		2	Y	7.52	7.52	7.52	15.95	15.95	15.95	N	WTP2 data
20/07/2022		2	Y	7.51	7.54	7.46	23.72	26.67	19.96	N	WTP2 data
21/07/2022		2	Y	7.22	7.22	7.22	23.09	23.09	23.09	N	WTP2 data
22/07/2022		2	Y	7.33	7.38	7.27	17.78	22.2	12.68	N	WTP2 data
23/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
24/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
25/07/2022		2	Y	7.01	7.01	7.01	27.58	27.58	27.58	N	WTP2 data
26/07/2022		2	Y	7.36	7.27	7.42	15.73	20.49	10.66	N	WTP2 data
27/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
28/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
29/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
30/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
31/07/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
Total for the month:	890.23										