	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Oct-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
2/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
3/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
4/10/2022		2	Y	8	8.1	7.9	6.3	6.3	6.3	N	WTP2 data
5/10/2022		2	Y	8	8.1	7.9	6.5	7.9	6.3	N	WTP2 data
6/10/2022		2	Y	6.5	6.5	6.5	20	20	19	N	WTP2 data
7/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
8/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
9/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
10/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
11/10/2022		2	Y	7.3	7.5	7.1	14.4	14.4	14.4	N	WTP2 data
12/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
13/10/2022		2	Y	7.2	7.4	7	13.7	114.4	12.5	N	WTP2 data
14/10/2022		2	Y	7.7	7.7	7.7	13.3	13.3	13.3	N	WTP2 data
15/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
16/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
17/10/2022		2	Y	7.4	7.6	7.2	18.7	26.2	12.5	N	WTP2 data
18/10/2022		2	Y	7.7	7.7	7.71	13.8	14.2	13.5	N	WTP2 data
19/10/2022		2	Y	7.5	7.5	7.5	7.7	7.7	7.7	N	WTP2 data
20/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
21/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
22/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
23/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
24/10/2022		2	Y	7.3	7.4	7.1	19.9	33.2	7.7	N	WTP2 data
25/10/2022		2	Y	7.4	7.4	7.4	16.5	16.5	16.5	N	WTP2 data
26/10/2022		2	Y	7.6	7.6	7.5	17.8	18.6	17	N	WTP2 data
27/10/2022		2	Y	7.6	7.7	75	10.9	29.8	6.3	N	WTP data
28/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
29/10/2022		2	Y	7.6	7.6	7.6	13.9	13.9	13.9	N	WTP2 data
30/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
31/10/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
Total for the month:	460.30										