	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Dec-22**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
2/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
3/12/2022		2	Y	7.0	7.0	7.0	10.5	10.5	10.4	N	WTP2 data
4/12/2022		2	Y	7.3	7.3	7.3	10.4	10.5	10.4	N	WTP2 data
5/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
6/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
7/12/2022		2	Y	6.8	6.8	6.8	10.9	10.9	10.9	N	WTP2 data
8/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
9/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
10/12/2022		2	Y	6.9	6.9	6.9	7.1	7.1	7.1	N	WTP2 data
11/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
12/12/2022		2	Y	7.1	7.5	6.8	9.3	12.8	7.6	N	WTP2 data
13/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
14/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
15/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
16/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
17/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
18/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
19/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
20/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
21/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
22/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
23/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
24/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
25/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
26/12/2022		2	Y	7.7	7.8	7.6	17.2	17.3	17.1	N	WTP2 data
27/12/2022		2	Y	7.8	8	7.6	17.3	17.4	17.2	N	WTP2 data
28/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
29/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
30/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
31/12/2022		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
Total for the month:	65.30										