	Water Treatment Plant - Water Discharge Monitoring Data Summary										
Month and Year	**Jan-23**										
Project	**Central Station Main Works**										
EPL Licence Number	**21148**										
EPL Weblink	https://centralstationmetro.com/documents/										
Specific EPL Monitoring Condition:	**M2.1- Pollutant Discharge**										
Date	**Volume of discharge (KL)**	**Discharge Point*** 1 = Stormwater 2 = Land**	**M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)**	**pH 6.5 - 8.5 log averaged**	**Highest pH**	**Lowest pH**	**TSS < 50 mg/L averaged**	**Highest TSS**	**Lowest TSS**	**Oil and grease present (Y/N)**	**Comments**
1/01/2023		2	Y	8.1	8.1	8.1	17.2	17.2	17.2	N	WTP2 data
2/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
3/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
4/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
5/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
6/01/2023		2	Y	6.8	6.9	6.7	16.8	19.5	13.4	N	WTP2 data
7/01/2023		2	Y	6.7	6.8	6.6	15.4	16.7	14.8	N	WTP2 data
8/01/2023		2	Y	6.8	6.8	6.8	11.2	11.2	11.2	N	WTP2 data
9/01/2023		2	Y	6.8	6.9	6.7	12.7	13	12.3	N	WTP2 data
10/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
11/01/2023		2	Y	7.3	7.3	7.3	6.3	6.3	6.3	N	WTP2 data
12/01/2023		2	Y	7.6	7.6	7.6	6.3	6.3	6.3	N	WTP2 data
13/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
14/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
15/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
16/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
17/01/2023		2	Y	8.3	8.3	8.2	6.3	6.3	6.3	N	WTP2 data
18/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
19/01/2023		2	Y	7.7	7.7	7.7	8.3	8.3	8.3	N	WTP2 data
20/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
21/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
22/01/2023		2	Y	6.8	6.8	6.8	6.3	6.3	6.3	N	WTP2 data
23/01/2023		2	Y	6.8	6.8	6.8	6.6	6.9	6.3	N	WTP2 data
24/01/2023		2	Y	7	7	7	6.4	6.6	6.3	N	WTP2 data
25/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
26/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
27/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
28/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
29/01/2023		2	Y	N/A	N/A	N/A	N/A	N/A	N/A	N/A	WTP2 data - No discharge
30/01/2023		2	Y	7.4	7.6	7.1	6.3	6	6.3	N	WTP2 data
31/01/2023		2	Y	7.2	7.2	7.2	9.5	9.9	9.3	N	WTP2 data
Total for the month:	20.10										